

Table 1
Analytical Results for Drinking Water Samples
Redmond School District
Deschutes County, Oregon
Farallon PN: 1445-003

Location	Sample Location	Date	Lead (mg/l)	Copper (mg/l)
Obsidian Middle School	Drinking Fountain	6/16/16	0.0001580	0.06220
	Kitchen	6/16/16	0.0054400	0.14600
Lynch Elementary School	Drinking Fountain	6/16/16	0.0001130	0.02040
	Kitchen	6/16/16	0.0010500	0.06420
Redmond High School	Drinking Fountain	6/16/16	0.0014100	ND
	Kitchen	6/16/16	0.0020800	0.02510
Brown Campus	Drinking Fountain	6/16/16	0.0002110	0.10700
	Kitchen	6/16/16	0.0073800	0.04800
	Kitchen Salad	6/16/16	0.0016600	0.03310
Tumalo Community School	Drinking Fountain	6/16/16	0.0030200	0.07700
	Kitchen	6/16/16	0.0080300	0.01420
Terrebonne Community School	Drinking Fountain	6/16/16	0.0001490	0.06020
Tuck Elementary School	Drinking Fountain	6/16/16	0.0026700	0.01880
	Kitchen	6/16/16	0.0022900	0.05960
EPA or State of Oregon Standard			0.015	1.3
MRL (Minimum Reporting Limit)			0.0001	0.01

ND - Not Detectable